## SAFETY DRGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 CSA CERTIFIED: CSA 22.2, #8 TUV APPROVED: EN60950

#### OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 30 AMP/55°C, 80 VDC

LINE FREQUENCY:

MAXIMUM LEAKAGE CURRENT,

EACH LINE TO GROUND: 120V 60Hz mA@ N/A mA@ 250V 50Hz

DPERATING AMBIENT TEMP. RANGE: -10°C TD +55°C @ RATED CURRENT, Ir.

IN AN AMBIENT,  $I_0$ , HIGHER THAN 55°C, THE MAXIMUM DPERATING CURRENT,  $I_0$ , IS AS FOLLOWS:  $I_0 = I_0 - \sqrt{85 - I_0}$  $I_0 = I_r$ 

#### RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +85°C HUMIDITY: 21 DAYS @ 40°C 95% RH. CURRENT DVERLDAD TEST: 6 TIMES Ir FOR 8 SECONDS

EC# APPRVD. IDDMMMY 0631-0093-03 11MAR03 11-006934 6JAN16 TAM

CATALOG # 30DCB6B

### TEST SPECIFICATIONS:

INDUCTANCE: 0.701 m H NDMINAL

CAPACITANCE: (MEASURED @ 1KHz, 0.250VAC MAX., 25°C±1°C)

0.093 μF ±20% 2.024 μF ±20% LINE TO GROUND: LINE TO LINE: DISCHARGE RESISTOR: 0.165M

L/G AND L/L I.R.

ND DISCHARGE RESISTOR: 6000M ← (MIN.) @ 100VDC,


20°C AND 50% RH

#### RECOMMENDED RECEIVING INSPECTION HIPOT:

2250 VDC FDR 1 MINUTE LINE TO GROUND: LINE TO LINE: 1450 VDC FOR 1 MINUTE

### FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.



50~(MINIMUM) INSERTION  $50\Omega$  $\Gamma \square Z Z$ FREQUENCY 01 . 05 0.1 .15 0.5 3 5 10 30 MHz COMMON 4 15 23 47 59 64 56 44 36 dΒ DIFF 22 28 31 32 59 56 51 28 41 dВ

THIRD ANGLE PROJECTION



UNLESS OTHERWISE SPECIFIED, TOLERANCE TO BE ±.025 MATERIAL & FINISH: AS SUPPLIED

This document is proprietary to CDRCDM INC and is not to be reproduced nor used for manufacturing purposes except on CDRCDM'S prior written consent.

*'Electronics* **&**Corcom 844 E. RDCKLAND RD. LIBERTYVILLE IL 60048

# POWER LINE FILTER

30DCB6B

E

1 0	11 TTA .	רא זיד רד	1 11 11	A T L A
			l # 2-1609074	<del>-</del> 7
ALE: NT	S DATE:	n-nn CATA	LDG ND.	REV.

P.III

PJD