# CERTIFICATE OF COMPLIANCE

Certificate Number
Report Reference

20130528-E13288 E13288-19880322

Issue Date

2013-MAY-28

Issued to:

TYCO ELECTRONICS CORP

2901 FULLING MILL RD MIDDLETOWN PA 17057

This is to certify that representative samples of

WIRE CONNECTORS AND SOLDERING LUGS

"UTILUX Slotted Ring and Spade" Pressure terminal connectors. Catalog numbers: H1289, H1289ET, H1289B, H1863D, H1863DDET, H1865, H2763, H2763ET, H3503, H3503ET, H3504, H3504ET, H3610, H3610ET, H3611, H3611ET, H3936, H3936ET, H3937, H3937ET, H3938,

H3938ET, H3946, H3947, H3948

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: Additional Information:

UL 486A-486B - Wire Connectors

See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Listing Mark should be considered as being covered by UL's Listing and Follow-Up Service.

The UL Listing Mark generally includes the following elements: the symbol UL in a circle: with the word "LISTED"; a control number (may be alphanumeric) assigned by UL; and the product category name (product identifier) as indicated in the appropriate UL Directory.

Look for the UL Listing Mark on the product.

William R. Carrey

William R. Camey, Director, North American Certification Programs

ny information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please ontact a local UL Customer Service Representative at <a href="https://www.ul.com/contactus">www.ul.com/contactus</a>



File E13288 Vol. 35

Sec. 2 and Report Page 1

Issued: 1988-03-22

Revised: 2013-05-28

## \_ \_ \_D\_E\_S\_C\_R\_I\_P\_T I O N

### PRODUCT COVERED:

Listed - "UTILUX Slotted Ring and Spade" Pressure terminal connectors, catalogs numbers tabulated below.

## GENERAL CHARACTER AND USE:

These are crimp-on, slotted terminals. They are for use with insulated, stranded, copper wire.

The crimp tool catalog numbers given are of hand tools and are illustrated in Figs. 2 and 3 where a "bench" crimp tool is indicated, crimps are to be made only on machine crimpers supplied with the proper catalog number die. Terminals suitable for hand crimp tool use may also be crimped in machine tools supplied with the correct die.

#### WIRE RANGE AND TOOLING:

Reference the indicated ILL. for material and dimensions information.

(No. of Wires) Cat. No. Wire Range, AWG Crimp Tool ILL. H1289, -ET, -B (1) 16-20 17 H1863D, -DET (1) 18-20 B-125-U H1865 (1) 18 B-125-U H2763, -ET (1) 18 B-125-U H3503, -ET (1) 14-18 17 H3504, -ET (1) 14-18 17 6 H3610, -ET 16-18 (1) 17 H3611, -ET (1) 16-18 17 7 H3936, -ET (1) 18 17 8 H3937, -ET (1) 18 17 8 H3938, -ET (1) 18 17 9 H3946 (1) 18 17 9 H3947 (1) 18 17 9 H3948 (1)17 18