



Certificate of Compliance

Certificate: 1572632 (LR 7189)

Master Contract: 164196

Project: 2249776

Date Issued: 2009/12/04

Issued to: Tyco Electronics Corporation

2100 Paxton St
Harrisburg, PA 17105-3608
USA
Attention: Mr. Cal Reed

The products listed below are eligible to bear the CSA Mark shown



Mike W. Gryschuk, C.E.T.

Issued by: Mike W. Gryschuk, C.E.T.

PRODUCTS

CLASS 6233 01 - RECEPTACLES - Attachment Plug Type and Plugs

Special-use connectors "AMP MULTIFITTING MARK II" Series 1241171, 1394556, 1534073, 1534078, rated 16A max, 250V; Series 1241170, 1394355, 1534072, 1534077, rated 10A max, 250V; Series 1241172, 1534075, rated 6A max, 250V.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 182.3-M1987 - Special Use Attachment Plugs, Receptacles, and Connectors



Supplement to Certificate of Compliance

Certificate: 1572632

Master Contract: 164196

The products listed, including the latest revision described below, are eligible to be marked in accordance with the referenced Certificate.

Product Certification History

Project	Date	Description
2249776	2009/12/04	One alternate body material Vydyne M344+ (item 1).
1592281	2004/09/30	Revised Cat. No. 1241170 to 1241171 for rating 16A max, 250V.
1572632	2004/07/08	Original Certification.



Descriptive Report and Test Results

MASTER CONTRACT: 164196

REPORT: 1572632

PROJECT: 2249776

Edition 1: July 8, 2004; Project 1572632 - Toronto
Issued by Richard Cohen, P. Eng.; Reviewed by Todd Hamden

Edition 2: September 30, 2004; Project 1592281 - Toronto
Issued by Richard Cohen, P.Eng.

Report Re-Issued

Edition 3: December 4, 2009; Project 2249776 - Toronto
Issued by Mike W. Gryschuk, C.E.T.

Report Reissued

Contents: Certificate of Compliance - Pages 1 to 1
Supplement to Certificate of Compliance - Page 1 to 1
Description and Tests - Pages 1 to 5
Figures - Figs 1 to 10

PRODUCTS

CLASS 6233 01 - RECEPTACLES - Attachment Plug Type and Plugs

Special-use connectors "AMP MULTIFITTING MARK II"
Series 1241171, 1394556, 1534073, 1534078, rated 16A max, 250V;
Series 1241170, 1394355, 1534072, 1534077, rated 10A max, 250V;
Series 1241172, 1534075, rated 6A max, 250V.

APPLICABLE REQUIREMENTS

CSA Std C22.2 No. 182.3-M1987 - Special Use Attachment Plugs, Receptacles, and Connectors

This report shall not be reproduced, except in full, without the approval of CSA International.

178 Rexdale Boulevard, Toronto, ON, Canada M9W 1R3
Telephone: 416.747.4000 1.800.463.6727 Fax: 416.747.4149 www.csa-international.org

MARKINGS

The Submitter's name/tradename/trademark and the CSA Mark are permanently marked on each device. The Submitter's identification, the CSA Mark, the Cat No, the electrical rating and the following (or equivalent) statements: "CAUTION: NOT FOR INTERRUPTING CURRENT" and "ATTENTION: NE PAS UTILISER POUR COUPER LE COURANT" are permanently marked on each device or in or on the smallest unit container or carton.

ALTERATIONS

See "Markings" above.

FACTORY TESTS

None.

DESCRIPTION

Conditions of Acceptability:

1. Supplied only to manufacturers, as components, for the assembly of Certified electrical equipment, where the acceptability of the suitability of the combination is determined in the end use.
2. Not for interrupting current.
3. Prefixes and suffixes maybe added to denote non-electrical variations.

Project 2249776: One alternate body material Vydyne M344+ by Ascend (item 1c).

Project 1592281: Revised Cat No 1241170 to 1241171 for rating 16A max, 250V.

Project 1572632: Original Certification.