



Certificate of Compliance

Certificate Number: LR 7189-A879

Revision:

Date Issued: December 15, 1997

Issued to: AMP Inc.
939 East Park Dr.
P.O. Box 3608, Mail Stop 210-20
Harrisburg, PA 17015-3608
Attention: Mr. James W. Love Jr.

The products listed below are eligible to bear the CSA Mark

Issued by: Nick Sajatovich
Toronto, ON Canada

Signature: *Nick Sajatovich*


PRODUCTS

CLASS NO 6233 01 - RECEPTACLES - Attachment Plug Type and Plugs

Special-Use Connectors, AMPOWER Multi-Pin Connectors, consisting of Plug Housing, Series 194070, 194183, 194196 and 194242; Receptacle Housing, Series 194069, 194182, 194197 and 194243; Pin Assembly, Series 194041, 194049 and 194189; Socket Assembly, Series 194032, 194037 and 194050, rated 15A, 20A, 25A, 30A and 150A, 250V ac and dc.

APPLICABLE STANDARDS

CSA Std. C22.2 No. 182.3-M1987 - Special Use Attachments Plugs, Receptacles and Connectors



Supplement to Certificate of Compliance

Certificate Number: LR 7189-A879

Issued to: AMP Inc.
939 East Park Dr.
P.O. Box 3608, Mail Stop 210-20
Harrisburg, PA 17015-3608
Attention: Mr. James W. Love Jr.


*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Issued By: Nick Sajatovich
Toronto, ON Canada

Signature 

Product Certification History

Revision	Date	Description
-A879	December 15, 1997	Original Certification



Descriptive and Test Report

Montréal ■ Toronto ■ Edmonton ■ Vancouver ■ Tokyo ■ Hong Kong

REPORT NO: LR 7189-A879

Edition 1: December 15, 1997; Application No LR 7189-A879 - Etobicoke
Issued by Nick Sajatovich

Contents: Pages - 1 to 3
Figures - 1 to 15
Attachments - 1 to 26 (UL Test Report)
1 (Test sheet)

MARKINGS

The manufacturer's name or trademark and the CSA Mark are stamped on each device. The catalogue number or designation, the electrical rating (volts and amperes), the wording "CAUTION: NOT FOR INTERRUPTING CURRENT" and ATTENTION: NE PAS UTILISER POUR COUPER COURANT and assembly or tooling instructions (if applicable) shall appear on the device or in or on the smallest unit container or carton.

ALTERATIONS

The products and cartons are marked as indicated above.

FACTORY TESTS

None required.

DESCRIPTION

Special Use Connectors, AMPPOWER Multi-Pin Connectors, consisting of Plug Housing, Series 194070, 194183, 194196 and 194242; Receptacle Housing, Series 194069, 194182, 194197 and 194243; Pin Assembly, Series 194041, 194049 and 194189; Socket Assembly, Series 194032, 194037 and 194050, rated 15A, 20A, 25A, 30A and 150A, 250V ac and dc.

Conditions of Acceptability:

1. These products are not for interrupting current.
2. The suitability of the mounting means, insulating materials, electrical and mechanical features of the wiring terminals and grounding termination shall be determined in the end use product.
3. These devices are intended to be used in electrical equipment where the operating temperature shall not exceed the temperature of the insulating materials.

General: These special use connectors are designed for the following wire sizes and ampere rating:

<u>WIRE SIZES(AWG)</u>	<u>AMPERE RATING</u>
14	15A
12	20A
10	25A
8	30A
1/0	150A