

CERTIFICATE

Issued to:
Applicant:
TE Connectivity Tyco Electronics UK Ltd
Faraday Road
Site H Dorcan
Swindon
Wiltshire SN3 5HH, Great Britain

Manufacturer/Licensee:
TE Connectivity Corporation
2901 Fulling Mill Road
Mail Stop 140-08
Middletown PA 17057, United States Of America

Product : Installation coupler
Trade name(s) : TE CONNECTIVITY
Type(s)/model(s) : Nector M-Line Sealed 7 pole PCB socket

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 61535:2009 and EN 61535:2009/A1:2013
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 2014487

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 14 July 2017 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-100885

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Henk Schendstok
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Installation coupler
Trade name(s)	: TE CONNECTIVITY
Type(s)/model(s)	: Nector M-Line Sealed 7 pole PCB socket
Rated current	: 20 A
Rated voltage	: 400 V~
Earthing	: with earthing contact
Design	: sealed 7 pole PCB installation
Degree of protection	: IP67
Terminals	: solder terminal
Description	: body of thermoplastic material

TESTS**Test requirements**

EN 61535:2009

EN 61535:2009/A1:2013

Test result

The test results are laid down in DEKRA test file 221674000.

Conclusion

The examination proved that all requirements were met.