

File E69543
Project 81ME12909

March 19, 1982

REPORT

on

COMPONENT, SUPPLEMENTARY PROTECTORS

Potter & Brumfield, Div. of AMF Inc.
Princeton, IN

Copyright © 1982 Underwriters Laboratories Inc.

Underwriters Laboratories Inc. authorizes the above named company to reproduce this Report provided it is reproduced in its entirety.

Underwriters Laboratories Inc. authorizes the above named company to reproduce that portion of this Report consisting of this Cover Page through Page 2.

DESCRIPTION

PRODUCT COVERED:

*Model W followed by 23 or 31, followed by X or E, followed by 1 or 2, followed by A, B, C, D, E, F, G, or M followed, by 1, 2, 3, 4, 5 or 6, followed by A, B, C, D, E, F, G, H or Z, followed by 0.5 through 50 inclusive.

SPECIAL VARIATIONS:

W23 or W31, followed by X, followed by 1000 through 1999 inclusive, may be followed by 0.5 through 50 inclusive or X1 through X99 inclusive.

GENERAL:

These devices are intended for use with office appliances, vending machines, data processing equipment, or similar appliances. These controls are of the open type, manual reset to close the circuit after automatic thermal opening as a results of an overload. They contain a "trip-free" feature which allows the external mechanism to open the contacts even though the breaker may be held manually in the reset position.

RATINGS:

*0.5 through 50 A, general use, 240 V ac, 50 V dc, or 80 V dc (10 A, E Series only).