

CERTIFICATE OF COMPLIANCE

Certificate Number 20170614-E308110
Report Reference E308110-20140415
Issue Date 2017-JUNE-14

Issued to: TYCO ELECTRONICS CORP
2901 FULLING MILL RD
MIDDLETOWN PA 17057-3170

This is to certify that representative samples of MULTI-POLE SPLICING WIRE CONNECTORS
Cool Splice, 293545-1, 293545-2, 293545-3, 293545-4,
2213800-1, 2213800-2, 2213800-3 and 2213800-4.

Have been investigated by UL in accordance with the Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 2459, Insulated multi-pole splicing wire connectors
CSA C22.2 No 2459-08, Insulated multi-pole splicing wire connectors

Additional Information: See the UL Online Certifications Directory at www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>



DESCRIPTION

PRODUCT COVERED:

USL, CNL - Cool Splice, 293545-1, 293545-2, 293545-3, 293545-4, 2213800-1, 2213800-2, 2213800-3 and 2213800-4.

GENERAL:

These devices are insulated multi-pole splicing wire connectors employing insulation-displacement type terminals, intended for field or factory assembly on to No. 18 AWG solid and stranded copper conductors for Cat. Nos. 293545-2, and 2213800-2, No. 20-22 solid and stranded for Cat. Nos. 293545-3, 2213800-3, 2213800-4 and 293545-4, No. 18 AWG Solid and Stranded conductors for Cat. Nos. 293545-1 and 2213800-1, as indicated. They are physically keyed to maintain correct polarity. These devices do not have provision for grounding. These devices are not luminaire disconnects intended for interrupting branch circuit. These devices are intended to be used in the branch circuit of a luminaire.

USL indicates investigation to United States Standard for Insulated Multi-Pole Splicing Wire Connectors, UL 2459.

CNL indicates investigation to the Canadian Standard for Insulated Multi-Pole Splicing Wire Connectors 04-15, CSA C22.2 No. 2459-08.

RATINGS:

Electrical -

Cat. No.	Voltage	Current
293545-1, 2213800-1, 293545-2, 2213800-2, 293545-3, 2213800-3, 293545-4, 2213800-4	600	6.2

Evaluated to UL 50E Enclosure Specifications with a 4X rating for use in Wet Locations.