SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROVED BY THE LISTED AGENCY, THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283

CSA CERTIFIEO: CSA C22.2, No. 8. VDE APPROVEO: EN 60939-2

OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 16 AMP, 120/250 VAC, 16 AMP/40°C, 250 VAC

LINE FREQUENCY:

50-60Hz

MAXIMUM LEAKAGE CURRENT,

EACH LINE TO GROUND:

0.76 mA@ 120V 60Hz 1.27 mA@ 250V 50Hz

DPERATING AMBIENT TEMP. RANGE: -10°C TO +40°C @ RATED CURRENT, In.

IN AN AMBIENT, To, HIGHER THAN 40°C, THE MAXIMUM OPERATING CURRENT, Io, IS AS FOLLOWS: I _ I _ I _ $\sqrt{100}$ - T-

/ 100 - Ta $I_0 = I_r -$

RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +100°C HEMIOITY: 21 DAYS @ 40°C 95% RH.
CURRENT OVERLOAD TEST: 6 TIMES I FOR 8 SECONOS

CATALOG # 16WGA1 ECN # | APPRVD. | DATE 09-020711 18SEP09

TEST SPECIFICATIONS:

INDUCTANCE: 0.54 mH NOMINAL

CAPACITANCE: (MEASURED @ IKHz, 0.250VAC MAX., 25°C±1°C)

LINE TO GROUND: LINE TO LINE:

0.02 µF ±20% 0.475 µF ±20%

DISCHARGE RESISTOR:

680K ∩

L/G AND L/L I.R.

NO DISCHARGE RESISTOR:

6000M₁ (MIN.) @ 100VDC.


20°C AND 50% RH


RECOMMENDED RECEIVING INSPECTION HIPOT:

LINE TO GROUND: 1500 VAC FOR 1 MINUTE 1450 VOC FOR 1 HINUTE LINE TO LINE:

FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.





50A-50A(TYPICAL) INSERTION LOSS												THIRD ANGLE	毫 Flackwarder
FREQUENCY MHz	.05	. 1	.15	,5	ı	2	5	10	20	30		UNLESS OTHERWISE SPECIFIED, TOLERANCE TO BE ±.025	Tyco Electronics CORCON PROCESSION, COD S. BUTTERFIELD FO. MANGEEIN IL COCCO POWER LINE FILTER TYCO ELECTRINICS PART ND: 2-1609089-4
COMMON d8	3	10	14	31	40	47	53	55	43	36		MATERIAL & FINISH: AS SUPPLIED	
OIFF.	13	19	23	33	40	53	51	42	53	53			SCALE: 0.75 DATE: 200CT04 CATALOG NO. REV. REV. P.JU 16WGA1 2