

Fuse box for lighting application EKM 2050 according to DIN 43628 / VDE 0660 T. 505 - with VDE-Symbol explanation SKF (for installation in lighting columns and outdoor application) - protection class II - ingress protection IP 54 - minimum diameter 89 mm - door opening minimum 85 x 270 mm - I x w x h: 257 x 82 x 63 mm - grey cover with screw - protection cover - compact- terminal block comprising: 2 fuse bases 16 A / D01-E 14, 2 fuses 6 A / E 14 2 screw caps E 14 5 sliding terminals rail connection (brass rails, nickel-plated) fully insulated PE- and N- output terminals entry terminals for 2 cables to 4 x 25 mm² or 3 cables to 5 x 16 mm² - type of mains: N, L1, L2, <L3>, PE

- extension of cable break out area (80 mm)
- pre- mounting earthing cable, 10 mm², green / yellow, 400 mm long, with ring cable lug for screw M 8
- 2 pole clamping screws M 6 x 12
- cable entry: cable clamp for 1 cable to 3 cables \varnothing 19-22 mm
- output: 2 cable glands, cable \oslash 8-14 mm


Two additional luminaire cables can be routed towards the bottom of the box.


22 19


24

24

circuit diagram:







D

63

