### SAFETY ORGANIZATIONS

THIS FILTER HAS BEEN FORMALLY RECOGNIZED, CERTIFIED OR APPROYED BY THE LISTED AGENCY. THEREFORE, ALL TEST/REQUIREMENTS SPECIFIED IN THE LATEST REVISION OF THE FOLLOWING AGENCY STANDARDS HAVE BEEN MET:

UL RECOGNIZED: UL 1283 CSA CERTIFIED: CSA 22.2, # 8 VDE APPROVED: EN 133200

### OPERATING SPECIFICATIONS

LINE CURRENT/VOLTAGE: 6 AMP/40°C, 120/250VAC

LINE FREQUENCY: 50-60Hz

MAXIMUM LEAKAGE CURRENT,

0.22mA@ 120V, 60Hz EACH LINE TO GROWND: 0.38mA @ 250V, 50Hz

OPERATING AMBIENT TEMP. RANGE: -10°C TO +40°C @ RATED CURRENT, Ic. IN AN AMBIENT,  $T_0$ , HIGHER THAN 40°C, THE MAXIMUM OPERATING CURRENT,  $I_0$ , IS AS FOLLOWS:  $I_0 = I_0 - \sqrt{100 - I_0}$  $I_0 = I_r - \sqrt{\frac{100 - T_0}{100}}$ 

### RELIABILITY SPECIFICATIONS:

STORAGE TEMPERATURE: -40°C TO +85°C HUMIDITY: 21 DAYS @ 40°C 95% RH. CURRENT DYERLOAD TEST: 6 TIMES In FOR 8 ZECONOS

# TEST SPECIFICATIONS:

INDUCTANCE: 0.93mH NOMINAL

0.275mH NOMINAL (GND CHOKE) CAPACITANCE: (MEASURED @ 1KHz, 0.250VAC MAX., 25°C±1°C)

LINE TO GROUND: 0.0053uF ±20% LINE TO LINE: 0.101µF ±20% DISCHARGE RESISTOR 1.5M L/G AND L/L I.R.

NO DISCHARGE RESISTOR: 6000Ma (MIN.) @ 100VDC,

20°C AND 50% RH

CATALOG # 6EGG8C-2

ECO # APPRVD. DATE

8N□V06

## RECOMMENDED RECEIVING INSPECTION HIPOT:

1500YAC OR 2250YDC FOR 1 MINUTE 1450YDC FOR 1 MINUTE LINE TO GROUND:

LINE TO LINE:

### FILTER APPROVAL:

THE BEST WAY TO SELECT AND QUALIFY A FILTER IS FOR YOUR ENGINEERING TO TEST THE UNIT IN YOUR EQUIPMENT.

