

DESCRIPTION

PRODUCT COVERED:

USL, CNL: Industrial control panels.

GENERAL:

The industrial control panels covered by this Procedure are custom-built assemblies with a maximum voltage rating of 600 V ac or dc, consisting of two or more components such as motor controllers, overload relays, fused disconnect switches, and/or circuit breakers and related control devices such as push button station, selector switches, timers, switches, control relays and the like with associated wiring, terminal blocks, pilot lights, etc. These panels are not intended for installation into hazardous locations or with circuits extending into hazardous locations.

CNL indicates investigation to Canadian Standard C22.2, No. 14-M95.

RATINGS:

Electrical Ratings - The industrial control panels covered by this Procedure are provided with electrical ratings for each input and output circuit in accordance with UL508A, Standard for Industrial Control Panels.

MARKINGS:

Each panel shall be marked in accordance with the requirements contained in UL508A, Standard for Industrial Control Panels.